WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86363
Permit No. 23614
Basin 105

NOTICE OF INTENT NO. 47962

1. OWNER Steve Sikora
MAILING ADDRESS 1000 Tillman Lane
Gardnerville, NV 89410

ADDRESS AT WELL LOCATION 1000 TILLMAN LANE
GARDNERVILLE NV 89410

2. LOCATION NE ¼ NW ¼ Sec. 16 T. 12 N/S R. 20 E. DOUGLAS County
PERMIT NO. 23614 (Issued by Water Resources) | 1220161010 07 (Parcel No.) | — (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☑ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Soil gravel cobbles	80	0	120	120
gravelly clay		120	180	60
gravel sand		180	380	200
clayey gravel		380	430	50
gravel sand		430	470	40
Granite boulders		470	600	130
Andesite boulders				

CASING SET
B +1 to 161 BLANK
P 161 to 201 Perf
B 201 to 222 BLANK
P 222 to 242 Perf
B 242 to 263 BLANK
P 263 to 283 Perf
B 283 to 304 BLANK
P 304 to 324 Perf
B 324 to 345 BLANK
P 345 to 365 Perf
B 365 to 385 BLANK
P 385 to 405 PERF
B 405 to 425 BLANK
P 425 to 445 Perf
B 445 to 465 BLANK
P 465 to 485 Perf
B 485 to 505 BLANK
P 505 to 525 perf
B 525 to 545 BLANK
P 545 to 565 perf
P 565 to 585 perf

Date started 1-13-02, 19
Date completed 2-13-02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
125+		6 hours

8. WELL CONSTRUCTION
Depth Drilled 600 Feet Depth Cased 585 Feet

HOLE DIAMETER (BIT SIZE) (15' of Slough)

Inches	From (Feet)	To (Feet)
10 5/8	0	600

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	

Perforations:
Type perforation Factory slot
Size perforation 3/32 x 3"
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 585 feet

9. WATER LEVEL
Static water level 69 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature COOL °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Nevada Drilling + Pump LLC (Contractor)
Address 3540 Green Acres Dr Carson City NV 89705 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 52078
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1902
Signed John B Reisch (By driller performing actual drilling on site or contractor)
Date 2-28-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627