

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 86374
 Permit No. _____
 Basin 061
 Page 1 of 2
 NOTICE OF INTENT NO. 43269

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

OWNER Barrick Goldstrike Mines PZ-99-14 ADDRESS AT WELL LOCATION Barrick Goldstrike
 MAILING ADDRESS P.O. Box 29 minesite, north of Carlin, NV.
Elko, NV 89803
 2. LOCATION NW 1/4 NE 1/4 Sec. 30 T 36N N/S R 50E E Eureka County
 PERMIT NO. N/A N/A N/A
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Original Construction Detail:				
Cement		0	50	50
Hole plug		50	490	440
Gravel pack		490	505	15
Hole plug		505	580	75
Cement		580	600	20
Hole plug		600	640	40
Gravel pack		640	655	15
Hole plug		655	690	35
Cement		690	710	20
Hole plug		710	730	20
Gravel pack		730	765	35

Abandoned by pumping each tube full of neat cement, T.D. to surface.

Used 29.5 cu. ft. of neat cement.

Date started 4/23/2002, 19
 Date completed 4/23/2002, 19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.		

8. WELL CONSTRUCTION
 Depth Drilled 765 Feet Depth Cased 740 Feet
 HOLE DIAMETER (BIT SIZE)
 From 14.75 Inches To 0 Feet 17 Feet
9.875 Inches 17 Feet 765 Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>10.75</u>	<u>28.014</u>	<u>0.250</u>	<u>0</u>	<u>17</u>
<u>1: 1.66</u>	<u>2.27</u>	<u>0.140</u>	<u>+1</u>	<u>740</u>
<u>2: 1.66</u>	<u>2.27</u>	<u>0.140</u>	<u>+1</u>	<u>650</u>

Perforations:
 Type perforation Mill Slot
 Size perforation 0.125" X 3"
 From 1: 735 feet to 740 feet
 From 2: 645 feet to 650 feet
 From 3: 495 feet to 500 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No
 Depth of Seal 50'
 Placement Method: Pumped Poured
 Seal Type: Neat Cement Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From See Notes feet to _____ feet

9. WATER LEVEL
 Static water level 1:446 2:354 3:354 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor
Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2039
 Signed Dennis Robblee
 By driller performing actual drilling on-site or contractor
 Date 5/3/02

RECEIVED
 02 MAY - 6 PM 1:56
 STATE ENGINEERING DIVISION

B.S.F.C