WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA

DIVISION OF WATER RESOURCES

Monitor Well #S1-3101

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86384
Permit No.
Basin 72

NOTICE OF INTENT NO. 43485

1. OWNER FLORIDA CANYON MINING, INC.
MAILING ADDRESS P.O. BOX 330
IMLAY, NV 89418

ADDRESS AT WELL LOCATION
HISTORIC STANDARD MINE AREA

2. LOCATION NW ¼ NW ¼ Sec. 1 T. 30 N N/S R. 33 E. PERSHING County
PERMIT NO. M/O 1229 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
XX New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial XX Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary XX RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
GRAY LIMESTONE		0	130	130
SILICIFIED LIMESTONE		130	135	5
GRAY LIMESTONE		135	175	40
SILICIFIED LIMESTONE		175	255	80
SILTSTONE		255	390	135
GRAY LIMESTONE		390	445	55
HOLE DRY - NO WATER				

Date started DECEMBER 18, 2001, 19
Date completed DECEMBER 19, 2001, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 445 Feet Depth Cased 445 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5 1/8 Inches	0 Feet	445 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	PVC	SCH 80	+2	445

Perforations:
Type perforation MILL SLOT PVC
Size perforation .020
From 100 feet to 445 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: XX Yes ☐ No
Depth of Seal 50
Placement Method: XX Pumped ☐ Poured

Seal Type: XX Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: XX Yes ☐ No
From 100 feet to 445 feet

9. WATER LEVEL
Static water level N/A DRY feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DELONG CONSTRUCTION & DRILLING (Contractor)
Address P.O. BOX 907 (Contractor)
WINNEMUCCA, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 0002120C
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 01375
Signed (By driller performing actual drilling on site or contractor)
Date Jan 14 2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627