

COPIES TO
 - DIVISION OF WATER RESOURCES
 - CLIENT'S COPY
 - WELL DRILLER'S COPY

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 864953
 Permit No. _____
 Basin 107
 NOTICE OF INTENT NO. 46419

PRINT OR TYPE ONLY

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER **ROB STINNETT CONSTRUCTION** ADDRESS AT WELL LOCATION **12 COLONY ESTATE DR**
 MAILING ADDRESS **P.O. BOX 2651** **WELLINGTON NV, 89443**
GARDNERVILLE, NV 89410

2. LOCATION SE 1/4 SE 1/4 Sec 34 T 11 N R 23 E LYON County
 PERMIT NO. 09/142/05

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other **MUD**

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
OVERBURDEN		0	4	4
HARDPAN CLAY		4	8	4
COURSE SANDS		8	13	5
BROWN CLAY		13	68	55
SILTY SANDS		68	95	27
BROWN CLAY		95	160	65
FRACTURED GRAVELS	XXX	160	190	30

8. WELL CONSTRUCTION

Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____
10 3/4 Inches 0 Feet 190 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>190</u>

Perforations:

Type perforation **FACTORY MILL SLOT**
 Size perforation **3 X 3/32**

From 170 feet to 190 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 190 feet

7. WELL TEST DATE

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>35</u>	<u>3 HRS</u>

9. WATER LEVEL

Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. 25 P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name **CAPITAL CITY WELL DRILLING**
 (CONTRACTOR)
 Address **20 KIT KAT DRIVE**
 (CONTRACTOR)
CARSON CITY, NV 89706
 Nevada contractor's license number issued by the State Contractor's Board 41775
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157

Signed Rick Crane
 By driller performing actual drilling on site or contractor
 Date 6/13/02

RECEIVED
 02 JUN 19 AM 9:17
 STATE ENGINEERS OFFICE