WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86455
Permit No.
Basin 212

NOTICE OF INTENT NO. 22820

1. OWNER County of Clark (Aviation)
MAILING ADDRESS P.O. Box 11005 Las Vegas NV. 89111-1005
ADDRESS AT WELL LOCATION 6022 Euclid Las Vegas NV

2. LOCATION SW ¼ NW ¼ Sec. 36 T. 21 N/S R. 61 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 162-36-202-019 Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☑ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Condition of well - Casing was rusty but in fair condition, Well was silted from 155'-180'				
Static water level was 24'				
Cleaned out well to Bottom at 180'				
Perforated well from 180 to Surface				
Perforations were 3" long by 3/8" wide				
Perforated 4 times per foot				
Well was plugged using tremie Hose from bottom of well with 24 sack neat cement from Rinker Mat. neat cement was pumped using bedrock pumping.				
Tremie Hose consisted of 2"x0.059' wall thickness				
Manufacture of Hose Sun Flow INC. Code SF-10				

DCNR/DWR
RECEIVED
JUL 11 2002
LAS VEGAS OFFICE

Date started 06-10, 2002
Date completed 06-20, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Knife
Size perforation 3" x 3/8"
From 180 feet to 0 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 24 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature Cool °F Quality Clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eagle Drilling Services (Contractor)
Address 7150 Placid Las Vegas NV 89119 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 51266
Nevada driller's license number issued by the Division of Water Resources, for on-site driller 2193
Signed Victor Lino (By driller performing actual drilling on site or contractor)
Date 06/24/02

(Rev. 12-01)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627