WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86488
Permit No.
Basin Ø87

NOTICE OF INTENT NO. **47858**

1. OWNER Park Tower Apartments-KL & J Management
MAILING ADDRESS 280 Island Ave
Reno, NV 89501

ADDRESS AT WELL LOCATION 280 Island Ave

2. LOCATION SW 1/4 SE 1/4 Sec. 11 T 19N N/S R 19E E Washoe County
PERMIT NO. 20103 Issued by Water Resources
011-471-01 Parcel No.
Subdivision Name

3. **WORK PERFORMED**
[ ] New Well [ ] Replace [ ] Recondition
[ ] Deepen [X] Abandon [ ] Other

4. **PROPOSED USE**
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
On this date we abandoned a 10" well x 221' deep. We perforated from 136' to about 80' at six perforations per foot. We were unable to perforate above the 80' level due to the construction of the well had been cemented in to 78'. We tried several places between 80' and surface with limited success. We were able to perforate about 5 different places with only one perforation. We pumped approximately 7 yards of neat cement mixed 5.2 gallons per sack from bottom to surface.				
Washoe Co. Permit # 6827				

Date started 5/8/2002 , 19__
Date completed 5/8/2002 , 19__

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. **WELL CONSTRUCTION**
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Mills Knife
Size perforation Puncture
From 136 feet to 80 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 221
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [ ] Yes [X] No
From ____ feet to ____ feet

9. **WATER LEVEL**
Static water level 17 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Bruce MacKay Pump & Well Service, Inc. (Contractor)
Address 1600 Mt. Rose Hwy (Contractor)
Reno, NV 89511
Nevada contractor's license number issued by the State Contractor's Board 23096
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1719
Signed R. Bruce MacKay (By driller performing actual drilling on-site or contractor)
Date 5/9/02

USE ADDITIONAL SHEETS IF NECESSARY