WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86522
Permit No.
Basin 162

NOTICE OF INTENT NO. 22244

1. OWNER PROVINCE
MAILING ADDRESS 3611 UNDERBRUSH
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 3611 UNDERBRUSH

2. LOCATION NW 1/4 SW 1/4 Sec. 31 T 20S N/S R 54 E NYE County
PERMIT NO. _____ Issued by Water Resources | 41-142-05 Parcel No. | CALVADA VALLEY Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	27	27
CLAY AND CALICHE		27	97	70
CALICHE	WB	97	108	11
CLAY		108	125	17
CALICHE	WB	125	134	9
CLAY		134	140	6

DCNR/DWR
RECEIVED
JUL 03 2002
LAS VEGAS OFFICE

Date started 6/24/2001, 19__
Date completed 6/26/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	250	0	140

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 0 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 66 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. OF NEVADA, INC.
Contractor
Address P.O. BOX 4220
Contractor
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed Ronald S Tously
By driller performing actual drilling on-site or contractor
Date 6/6/02

USE ADDITIONAL SHEETS IF NECESSARY