

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 86560  
 Permit No. \_\_\_\_\_  
 Basin 162

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **22239**

1. OWNER **PAHRUMP CONCRETE** ADDRESS AT WELL LOCATION **1240 LEWIS**  
 MAILING ADDRESS **1240 LEWIS**  
**PAHRUMP, NV 89048**

2. LOCATION NE 1/4 NE 1/4 Sec. 14 T 21S N/S R 53E E NYE County  
 PERMIT NO. \_\_\_\_\_ ISSUED BY Water Resources Parcel No. **44-701-15** Subdivision Name **MESA OESTE**

3. WORK PERFORMED  New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock \_\_\_\_\_  
 5. WELL TYPE  Cable  Rotary  RVC  Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	44	44
CALICHIE		44	54	10
CLAY		54	78	24
CALICHIE	WB	78	84	6
CLAY		84	102	18
CALICHIE	WB	102	113	11
CLAY		113	129	16
CALICHIE	WB	129	136	7
CLAY		136	140	4

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10.25 Inches To 0 Feet  
 From 0 Feet To 140 Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet  
 From \_\_\_\_\_ Inches To \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	3.63	.280	0	140

Perforations:  
 Type perforation **SAW CUT**  
 Size perforation **1/8 X 3**  
 From 100 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 67 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 6/14/2001, 19\_\_\_\_  
 Date completed 6/15/2001, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.		Time (Hours)
	Bailer	Pump	
<input type="checkbox"/> Bailer	Draw Down (Feet Below Static)	<input type="checkbox"/> Pump	<input type="checkbox"/> Air Lift

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **GREAT BASIN DRILLING CO. OF NEVADA, INC.** Contractor  
 Address **P.O. BOX 4220** Contractor  
**PAHRUMP, NV. 89048**  
 Nevada contractor's license number issued by the State Contractor's Board **47333**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1642**  
 Signed Thomas Dan  
 By driller performing actual drilling on-site or contractor  
 Date **6/16/01**

