

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 84015
 Permit No. _____
 Basin 087

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **50866**

1. OPERATOR Truckee Meadows Water Authority Pah Rah Park
 MAILING ADDRESS P.O. Box 30013
Reno, NV 89520-3013

ADDRESS AT WELL LOCATION Jerry Whitehead School,
Sparks, NV.

2. LOCATION NW 1/4 NW 1/4 Sec. 35 T 20N N/S R 20E E Washoe County
 PERMIT NO. 66399 Issued by Water Resources Parcel No. 030-161-13 Subdivision Name N/A

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Abandoned this well by perforating from 100 to 270', with six passes of the perforator, then pumped abantonite via tremie from the bottom of the well to 40', and capped with neat cement to surface. Cement settled 15' overnight, and was topped off two days later to 4' below grade. 12" casing cut off at 4' b.g.s.				
Quantities Used:				
Cement: 67.3 cu.ft.				
Abantonite: 468 cu.ft.				

8. WELL CONSTRUCTION
 Depth Drilled 480 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>28</u> Inches	<u>0</u> Feet	<u>50</u> Feet	<u>50</u> Feet
<u>17.5</u> Inches	<u>50</u> Feet	<u>480</u> Feet	<u>480</u> Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>20</u>	<u>78.6</u>	<u>0.375</u>	<u>0</u>	<u>50</u>
<u>12.75</u>	<u>43.77</u>	<u>0.330</u>	<u>+3</u>	<u>460</u>

Perforations:
 Type perforation Wire Wrap
 Size perforation 0.080"
 From 270 feet to 410 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 480 feet

9. WATER LEVEL
 Static water level 34.5 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature Cool °F Quality Fair

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling Contractor
 Address P.O. Box 5279 Contractor

Elko, NV 89802-5279
 Nevada contractor's license number issued by the State Contractor's Board 0021976

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1410

Signed John Viegutz
 By driller performing actual drilling on-site or contractor
 Date 7/23/02

Date started 7/13/2002, 19
 Date completed 7/15/2002, 19

7. WELL TEST DATA

TEST METHOD:	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	
	G.P.M.	Time (Hours)
	Draw Down (Feet Below Static)	

B.S.F.A