WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86643
Permit No.
Basin 212

NOTICE OF INTENT NO. 22645

1. OWNER Kiewit Western
MAILING ADDRESS 1111 Mary Crest Rd. Suite F Henderson, NV 89074
ADDRESS AT WELL LOCATION Northshore Rd. & Las Vegas Wash

2. LOCATION NE ¼ SE ¼ Sec. 14 T. 21 N/S R. 63 E. Clark County
PERMIT NO. OW-1146 Issued by Water Resources
160-14-801-001 Parcel No.
Las Vegas Wash Bridge Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE Temp Dewatering
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other Bucket Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
well #1				
Fill		0	3'	3'
Sands & Gravel		3'	15'	12'
Silty Clay		15'	17'	2'
Sands & Gravel		17'	21'	4'
Silty Sands		21'	30	9'
well # 2 - Same as #1				
Well # 3 - Same as #1				
Last well to be Drilled.				
Drilled 32 wells out of 40 that were Requested on Intent to Drill Card				

Date started 5-17, 2002
Date completed 5-17, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
24"	0	30'

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12"	PVC	Sch - 40	0	10'

Perforations:
Type perforation Saw Cut
Size perforation .032
From 10' feet to 30' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 0 feet to 30' feet

9. WATER LEVEL
Static water level 8' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Griffin Dewatering Contractor
Address 536 E. Maitland Street Contractor
Ontario CA 91761
Nevada contractor's license number issued by the State Contractor's Board 0031246
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 11-1985
Signed By driller performing actual drilling on site or contractor
Date 5-17-02

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627