WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86650
Permit No.
Basin 108

NOTICE OF INTENT NO. 21185

1. OWNER Don Tibbals
MAILING ADDRESS 2 Austin Road
Yerington, Nevada 89447

ADDRESS AT WELL LOCATION 2 Austin Road
Yerington, Nevada 89447

2. LOCATION NW ¼ SE ¼ Sec. 28 T. 13 (N)/S R 25 E Lyon County
PERMIT NO. ..... Issued by Water Resources ..... Parcel No. ..... Weed Heights Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand, Broken Rock, Silt		0	48	48
Clay, Broken Rock		48	59	11
Clay, Sand		59	71	12
Multicolor Broken Rock		71	180	109
Broken Rock, Clay		180	211	31
Broken Rock		211	290	79
Broken Rock, Clay		290	300	10
Brown Clay, Small Broken Rock		300	460	160
Red Consolidated Rock		460	503	43
Well Abanoned To Plug and Cyspan - Weight 10.33	Full Depth Viscosity	With 90	Hole Second	

Date started August 10, 1992
Date completed August 17, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

SEP 14 P12:06
'92
STATE ENGINEERS

8. WELL CONSTRUCTION
Depth Drilled 503 Feet Depth Cased 0 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
7 7/8 Inches	Ø Feet	503 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation
Size perforation
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sargent Irrigation Company (Contractor)
Address 9955 North Virginia Street (Contractor)
Reno, Nevada 89506

Nevada contractor's license number issued by the State Contractor's Board 21246

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1540

Signed Dan Tranger
By driller performing actual drilling on site or contractor

Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627