

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19753

1. OWNER Tom Wipfli Const. ADDRESS AT WELL LOCATION None Listed  
 MAILING ADDRESS Wellington NV  
 2. LOCATION NE 1/4 SE 1/4 Sec 33 T 11 N/S R 24 E Lyon County  
 PERMIT NO. 55085 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVE  
 Air  Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Bj Old Sand</u>		<u>0</u>	<u>2</u>	<u>2'</u>
<u>Clay</u>		<u>2</u>	<u>4</u>	<u>2'</u>
<u>Sand + Course Gravels</u>		<u>4</u>	<u>35</u>	<u>31'</u>
<u>Clay w/ in bedded Gravels</u>		<u>35</u>	<u>165</u>	<u>130'</u>
<u>Gravels w/ clay seams</u>		<u>165</u>	<u>200</u>	<u>35'</u>
<u>Clay</u>		<u>200</u>	<u>240</u>	<u>40'</u>
<u>Cemented Boulders (Hard)</u>		<u>240</u>	<u>270</u>	<u>30'</u>
<u>Course gravels w/ Clay Seams</u>	<u>xxx</u>	<u>270</u>	<u>320</u>	<u>50'</u>
<u>Water Gravels</u>	<u>xxx</u>	<u>320</u>	<u>355</u>	<u>35'</u>
<u>Large gravels</u>	<u>xxx</u>	<u>355</u>	<u>370</u>	<u>15'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 0 Feet Depth Cased 370' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From, To  
16 Inches 0' Feet 55' Feet  
12 3/4 Inches 55' Feet 370' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>23.57</u>	<u>.250</u>	<u>0</u>	<u>370</u>

Perforations:  
 Type perforation Mill Slot  
 Size perforation 3/32  
 From 150 feet to 370 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 100  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 370 feet

Date started 9/17 1992  
 Date completed 9/21 1992

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>150+</u>		<u>3 Hr.</u>

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 150+ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A.H. Pump Co. Contractor  
 Address 5551 Hwy 50E #3 Contractor  
C.C. W. 89701  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1472  
 Signed Quinton R. Butts  
 By driller performing actual drilling on site or contractor  
 Date 9/21/92