WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86660-9
Permit No.
Basin 212

NOTICE OF INTENT NO. 23366

1. OWNER CLARK COUNTY SANITATION DISTRICT
MAILING ADDRESS
ADDRESS AT WELL LOCATION PROPOSED EFFLUENT INTERCEPTOR NEAR LAS VEGAS WASH

2. LOCATION NE ¼ SW ¼ Sec. 30 T. 21 N/S R. 63 E. CLARK County
PERMIT NO. (Issued by Water Resources) 160-30-000-002 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAYEY SAND		0	9	9
SILTY CLAY		9	17	8
CLAY WITH GRAVEL		17	22	5
CONGLOMERATE		22	56.4	34.4
MUDSTONE		56.4	71.6	15.2
GYPSIFEROUS MUDSTONE		71.6	116	44.4
SILTY MUDSTONE W/ GYP		116	126	10
MUDSTONE W/ GYP		126	133	7
SILTY MUDSTONE WITH GYPSUM		133	171.6	38.6

Date started 5/8/02, 19
Date completed 5/9/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 172.3 Feet Depth Cased 167.9 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
4 ½	0	172.3

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	167.9

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 157.9 feet to 167.9 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 151
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 151 feet to 170 feet

9. WATER LEVEL
Static water level 0.60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CONVERSE CONSULTANTS (Contractor)
Address 731 PILOT ROAD, STE #1 (Contractor)
LAS VEGAS, NV 89119
Nevada contractor's license number issued by the State Contractor's Board 48947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627