WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86670
Permit No.
Basin 212

NOTICE OF INTENT NO. 23363

1. OWNER CLARK COUNTY SANITATION DISTRICT
MAILING ADDRESS
ADDRESS AT WELL LOCATION PROPOSED CROSSING OF EFFLUENT INTERCEPTOR AND LAS VEGAS WASH

2. LOCATION SE ¼ SW ¼ Sec. 30 T. 21 N/S R. 63 E. CLARK County
PERMIT NO. (Issued by Water Resources) | Parcel No. 160-30-000-003 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAYEY SAND		0	4	4
SANDY GRAVEL		4	8	4
SILTY SAND		8	11	3
SANDY GRAVEL		11	12	1
CLAYEY SAND		12	15	3
SILTY SAND		15	22	7
CLAY		22	32	10
SANDY GRAVEL		32	42	10
CLAYEY GRAVEL		42	45	3
SAND		45	51	6
BASALT		51	53	2
MUDSTONE		53	56.7	3.7
MUDSTONE W/ GYPSUM		56.7	135	78.3
SILTY MUDSTONE WITH GYPSUM		135	141	6
MUDSTONE WITH GYPSUM		141	170	29

Date started 5/7/02, 19
Date completed 5/9/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
4 1/2	0	170

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		SCH 40	0	169

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020 INCH
From 159 feet to 169 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 157
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 157 feet to 170 feet

9. WATER LEVEL
Static water level 8.45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CONVERSE CONSULTANTS (Contractor)
Address 731 PILOT ROAD STE H (Contractor)
LAS VEGAS, NV 89115
Nevada contractor's license number issued by the State Contractor's Board 48547
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627