WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86708
Permit No.
Basin 212

NOTICE OF INTENT NO. 22771

1. OWNER Quincy & Gretchen Vineyard
MAILING ADDRESS ~~1911~~ Vineyard Rd. 9911
HCR38, Las Vegas, Nev. 89124

ADDRESS AT WELL LOCATION
Same 9911 Vineyard

2. LOCATION NW ¼ SW ¼ Sec. 2 T. 19S N/S R. 59 E. Clark County
PERMIT NO. (Issued by Water Resources) 126-02-301-003 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	22	
Cemented Gravel		22	25	
Gravel		25	50	
Cemented Gravel		50	545	
Boulders		545	575	
Cemented Gravel		575	600	
Reddish Sandstone and Gravel		600	740	
Gravel & Boulders		750	790	
Gravel & Water	xx	790	800	
Cemented Gravel		800	850	
Gravel & water	xx	850	895	

DCNR/DWR
RECEIVED
MAY 2 2002
LAS VEGAS OFFICE

Date started 5/13/02, 19
Date completed 5/25/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 895 Feet Depth Cased 895 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	53 Feet
9 7/8 Inches		53 Feet	895 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	2	53
6 1/2	SRD PVC		+1	895

Perforations:
Type perforation Factory
Size perforation Sieve type .020
From 855 feet to 895 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 53
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 710 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 Bonita Vista (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 05-25-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627