

OFFICE USE ONLY
 Log No. 86731
 Permit No. _____
 Basin. 212
 B-2
 NOTICE OF INTENT NO. 22019

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER 1195 E. DESERT INN ROAD LLC. ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1517 S. SEPULVEDA BLVD 3319 & 3333 S. MARYLAND PARKWAY
LOS ANGELES, CA 90025 LAS VEGAS, NV 89109
 2. LOCATION NE 1/4 NE 1/4 Sec. 15 T. 21 N10R 61E CLARK County
 PERMIT NO. 162-15-503-003 Issued by Water Resources 162-15-503-004 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ASPHALT		0	0.3	0.3
SILTY CLAY / FINE SILT WITH CLAY		0.3	6	5.7
SILTY CLAY WITH CAUCHE		6	12	6
SILTY CLAY WITH CAUCHE AND GRAVEL		12	15	3
SILTY CLAY		15	18	3
		18	35	17

CONTRACTOR RECEIVED
 LAS VEGAS OFFICE

8. WELL CONSTRUCTION
 Depth Drilled 35 Feet Depth Cased 35 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 Inches _____ Feet _____
 Inches _____ Feet _____
 Inches _____ Feet _____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>SC4 40</u>	<u>0</u>	<u>35</u>

Perforations:
 Type perforation FALLOUT SLOT
 Size perforation 0.10 INCH
 From 5 feet to 35 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 35 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 3.5 feet to 35 feet

9. WATER LEVEL
 Static water level 20 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name CONVERSE CONSULTANTS Contractor
 Address 731 PILOT ROAD, STE H LAS VEGAS, NV 89119 Contractor
 Nevada contractor's license number 48947 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
 Signed Ronald J. [Signature] By driller performing actual drilling on site or contractor
 Date _____

Date started 8/28/02, 19____
 Date completed 9/18/02, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			