WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86734
Permit No.
Basin 212
B-5
NOTICE OF INTENT NO. 22019

1. OWNER 1195 DESERT INN ROAD, LLC
MAILING ADDRESS 1517 S. SEPULVEDA BLVD
LOS ANGELES, CA 90025

ADDRESS AT WELL LOCATION 3319 & 3333 SO. MARYLAND PARKWAY
LAS VEGAS, NV 89109

2. LOCATION NE ¼ NE ¼ Sec. 15 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. Issued by Water Resources 162-15-503-003 162-15-503-004 Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.3	0.3
SILTY CLAY / FILL		0.3	6	5.7
SILTY CLAY WITH GRAVEL		6	13	7
SILTY CLAY WITH CALICHE		13	16	3
SILTY CLAY		16	22	6
CLAY WITH SILT		22	35	13

DCNR/DWR RECEIVED
LAS VEGAS OFFICE

Date started 8/28/02, 19
Date completed 9/1/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	35 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"		SCH 40	0	35

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.10
From 5 feet to 35 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 5
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 35 feet to 35 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name CONVERSE CONSULTANTS (Contractor)
Address 731 PILOT ROAD STE A (Contractor)
LAS VEGAS, NV 89109
Nevada contractor's license number issued by the State Contractor's Board 40947
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1595
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627