WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86838
Permit No.
Basin 1002

NOTICE OF INTENT NO. 22240

1. OWNER PAHRUMP CONCRETE
MAILING ADDRESS 4451 JOANN
PAHRUMP, NV 89048

ADDRESS AT WELL LOCATION 4451 JOANN

2. LOCATION SW 1/4 NE 1/4 Sec. 23 T 20S N/S R 52 E NYE County
PERMIT NO. (Issued by Water Resources) 41-443-15 (Parcel No.) GOLDEN SPRING RANCH (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY AND CALICHE		0	70	70
CALICHE	WB	70	85	15
CLAY		85	97	12
CALICHE	WB	97	115	18
CLAY		115	123	8
CALICHE	WB	123	140	17

DCNR/DWR
RECEIVED
JUN 25 2002
LAS VEGAS OFFICE

Date started 6/16/2001, 19__
Date completed 6/18/2001, 19__

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10.25	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6	3.63	2.280	0	140

Perforations:
Type perforation SAWCUT
Size perforation 1/8 X 3
From 0 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING (Contractor)
Address P.O. BOX 4220 (Contractor)
PAHRUMP,NV. 89048
Nevada contractor's license number issued by the State Contractor's Board 47333
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2063
Signed Thomas Dean (By driller performing actual drilling on-site or contractor)
Date 6/6/02

USE ADDITIONAL SHEETS IF NECESSARY