

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 22444

1. OWNER Mark E. Wadco Eagle Sand & Gravel ADDRESS AT WELL LOCATION 5 miles E Valley C.F. Fire Tuff
 MAILING ADDRESS _____

2. LOCATION NE 1/4 SE 1/4 Sec 10 T. 17 N/S R. 65 E Clark County
 PERMIT NO. 66319-7 66320 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Well was plugged back from 1700' to 426' with Neat Cement				
Sand & Gravel		0	25	25
Sand Gravel + Silt + Clay		25	360	335
lime stone + sand Gravel		360	400	40
Sand gravel + Clay		400	426	26

8. WELL CONSTRUCTION
 Depth Drilled 426 Feet Depth Cased 427 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To _____ Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 1/2</u>		<u>1.323</u>	<u>0</u>	<u>426</u>

Perforations:
 Type perforation mill slot .050
 Size perforation _____
 From 192 feet to 363 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement
 Depth of Seal 50 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 426 feet to 50 feet

9. WATER LEVEL
 Static water level 378 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 79 °F Quality Good

Date started 5-30-2001
 Date completed 7-30-2001

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Christensen Contractor
 Address 12030 E Riggs Rd. Chandler AZ 85249
 Nevada contractor's license number issued by the State Contractor's Board 0019101
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2021
 Signed Mark E. Wadco
 By driller performing actual drilling on site or contractor
 Date 9-25-2001