WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86936
Permit No.
Basin ~~164A~~ 163

NOTICE OF INTENT NO. 22930

1. OWNER John + Peggy Ellenburg
MAILING ADDRESS
ADDRESS AT WELL LOCATION Shoshone St. + Granite Av. Sandy Valley NV.

2. LOCATION SE¼/NE ¼ NE¼/SW ¼ Sec. 22 T. 24 N R. 56 E. Clark County
PERMIT NO. Issued by Water Resources | Parcel No. 200-22-301-011 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	2	2
Clay		2	22	20
Calichie		22	25	3
Clay		25	48	23
Calichie		48	52	4
Clay		52	62	10
Calichie		62	69	7
Clay		69	80	11
Calichie		80	83	3
Clay		83	93	10
Calichie	W.B	93	101	8
Clay		101	120	19
Calichie	W.B	120	128	8
Limestone w/Fracture	W.B	128	140	12

DONE/DWR RECEIVED JUN 07 2002 LAS VEGAS OFFICE

Date started 5-21, 2002
Date completed 5-29, 2002

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
10 5/8 Inches From 0 Feet To 140 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	4.33	.316	0	140

Perforations:
Type perforation Saw Cut
Size perforation ⅛ inch By 6 inch
From 140 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 140 feet to 50 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Budget Drilling Co. (Contractor)
Address P.O. Box 3505 (Contractor)
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 40020
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed [signature] By driller performing actual drilling on site or contractor
Date 5-30-2002

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627