WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 86951
Permit No.
Basin 212

NOTICE OF INTENT NO. 23099

1. OWNER TURNBERRY PAVILION PARTNERS
MAILING ADDRESS 2777 PARADISE RD. LAS VEGAS, NV 89109
ADDRESS AT WELL LOCATION 2777 PARADISE RD. 23099 LAS VEGAS, NV 89109

2. LOCATION NE ¼ SE ¼ ¼ Sec. 9 T. 21 N/S R. 61 E/W CLARK County
PERMIT NO. DW1148 (Issued by Water Resources) 162-09 602-007 (Parcel No.) ~~XXXXXXXX~~ TOWER III (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other

4. PROPOSED USE Dewater
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
8-30' DEWATER WELLS				
Fill		0'	2'	
Caliche		2'	4'	
Clay, silt, brown-dry		4'	12'	
Clay, sand & gravel-wet		12'	22'	
Brown clay-dry		22'	27'	
Brown clay sand with gravel		27'	29'	
Caliche		29'	35'	
Clay, sand & gravel-wet		35'	45'	
Sandy silt		45'	50'	

DCNR/DWR
RECEIVED
AUG 1 9 2002
LAS VEGAS OFFICE

Date started 6/6/02, 19
Date completed 6/13/02, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 30' Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)
Inches From Feet To Feet
Inches From Feet To Feet
Inches From Feet To Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
14	36.71	1.250	0	30

Perforations: MACHINE
Type perforation 1/4" x 2 1/2" x 3 rows @ 13
Size perforation 10 30
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ALLEN DRILLING INC. (Contractor)
Address 4847 S. VALLEY VIEW (Contractor)
LAS VEGAS, NV 89103
Nevada contractor's license number 18917 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1301 T-1
Signed (By driller performing actual drilling on site or contractor)
Date June 17, 2002

(Rev. 3-01) So. NV Reg

USE ADDITIONAL SHEETS IF NECESSARY

101-627