WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 86987
Permit No.
Basin 203

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 21678

1. OWNER RICK BROWN
MAILING ADDRESS P.O. BOX 571
CALIENTE NV 89008

ADDRESS AT WELL LOCATION SKY LANE
CALIENTE

2. LOCATION SE ¼ NW ¼ Sec. 10 T. 3 N/S R. 67 E. LINCOLN County
PERMIT NO. (Issued by Water Resources) Parcel No. 13-150-20 Subdivision Name INDIAN RIDGE

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BOULDERS		0	6	6
WHITE TUFF		6	11	5
HARD RED CLAY		11	24	13
WHITE CLAY		24	28	4
HARD BROWN CLAY		28	46	18
HARD SANDSTONE		46	49	3
RED SANDY CLAY		49	83	34
HARD BROWN CLAY		83	97	14
RED CLAY		97	122	25
HARD SANDSTONE		122	127	5
SANDY BROWN CLAY		127	175	48
STICKY RED CLAY		175	224	49
HARD RED SANDST.		224	228	4
BEDDED SAND AND GRAVEL	228	228	290	62

Date started 02-MARCH 2002, 19—
Date completed 22-APRIL 2002, 19—

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 8 Draw down 5± feet 4 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 3/4 inches Total depth 290 feet
8 3/4 inches
inches
Casing record 5 INCH ID CERTA-LOCK
Weight per foot Thickness SDR 21

Diameter	From	To
5 inches	+2 feet	290 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐, Type CONCRETE
Depth of seal 50.5 feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50.5 feet to 290 feet

Perforations:
Type perforation BLADE - VERTICAL
Size perforation 1/8" x 6"
From 290' feet to 230' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 215 feet below land surface
Flow 11.5 G.P.M. 34 P.S.I.
Water temperature 58 °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JACK FREELAND (BULLEYE DRILL LLC) Contractor
Address P.O. BOX 2138, PAHRUMP NV 89041 Contractor
Nevada contractor's license number issued by the State Contractor's Board 50941
Nevada contractor's driller's number issued by the Division of Water Resources 2064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2064
Signed Jack Freeland
By driller performing actual drilling on site or contractor
Date 27-APRIL-2002

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627