WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87017
Permit No.
Basin 212

NOTICE OF INTENT NO. 24003

1. OWNER Abel S. Ramos
MAILING ADDRESS
ADDRESS AT WELL LOCATION ~~Vacant~~ 4965 DAPPLE GRAY RD.

2. LOCATION ~~NE~~ SW ¼ ~~NW~~ SW ¼ Sec. 32 T. 19S N/S R. 60 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. 125-32-401-002 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	50	
Cemented Gravel		50	100	
Clay & Gravel		100	200	
Cemented Gravel		200	240	
Clay & Gravel		240	300	
Cemented Gravel		300	345	
Gravel & Water	xx	345	360	
Cemented Gravel		360	400	
Gravel & Water	xx	400	420	
Cemented Gravel		420	460	
Gravel & Water	xx	460	510	

NOV 2002
RECEIVED
LAS VEGAS OFFICE

Date started 10/2/02, 20
Date completed 10/7/02, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 510 Feet Depth Cased 510 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/2 Inches	0 Feet	50 Feet	
8 3/4 Inches	50 Feet	510 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	510
6 1/2	Plastic	SDR	+1	510

Perforations:
Type perforation Factory
Size perforation .020 Sieve type
From 430 feet to 450 feet
From 470 feet to 490 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 315 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick (Contractor)
Address 5360 Bonita Vista St. (Contractor)
Las Vegas, Nev. 89149
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 10-07-02

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627