

OFFICE-USE ONLY  
 Log No. 87030  
 Permit No. \_\_\_\_\_  
 Basin 212  
 NOTICE OF INTENT NO. 22014

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER IAN SCHLEGEL HOTELS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 475 TENTH AVE 1605 FLAMINGO RD  
NEW YORK CITY, NY 10018 LAS VEGAS, NV 89109  
 2. LOCATION SE 1/4 Sec. 16 T. 21 N. 61 E. County \_\_\_\_\_  
 PERMIT NO. 162-16-410-056 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	3	
Gravel		3	7	
Silty clay		7	10	
Gravel		10	11	
Clay & sand		11	15	
Gravel		15	21	
Gravel & clay		21	26	

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

8. WELL CONSTRUCTION  
 Depth Drilled 26 Feet Depth Cased 26 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 5 1/2 Inches To 26 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.375</u>		<u>0.308</u>	<u>0</u>	<u>2</u>

Perforations:  
 Type perforation Factory slot PVC  
 Size perforation 0.020  
 From 5 feet to 26 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 5  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 5 feet to 26 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet/below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Concepcion Contreras Contractor  
 Address 731 PLOT RD STE H  
LAS VEGAS, NV 89119 Contractor  
 Nevada contractor's license number 48947  
 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the M1589  
 Division of Water Resources, the on-site driller.  
 Signed Ronald J. Wilson  
 By driller performing actual drilling on site or contractor  
 Date 10/7/02