

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 87154
 Permit No. 66200
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24226

OWNER GREEN GALE PROPERTIES
 MAILING ADDRESS 6722 N RAINBOW
LAS VEGAS, NV

ADDRESS AT WELL LOCATION TENAYA & ELKHORN

2. LOCATION NW 1/4 NE 1/4 Sec. 22 T 19S N/S R 60E E CLARK County
 PERMIT NO. 66200 125-22-501-001
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	6	6
CALICHIE		6	10	4
CLAY		10	30	20
LIMESTONE		30	37	7
CLAY		37	66	29
LIMESTONE		66	72	6
CLAY		72	124	52
CALICHIE		124	136	12
CLAY		136	154	18
CALICHIE		154	162	8
CLAY		162	189	27
CALICHIE		189	200	11
CLAY		200	230	30
CALICHIE		230	240	10
CLAY		240	340	100
CALICHIE	WB	340	347	7
CLAY		347	365	18
CALICHIE	WB	365	379	14
CLAY & CALICHIE		379	485	106
CALICHIE	WB	485	618	133
SEALED AT 225 TO 240 FT WITH BENTONITE PELLETS				
DCNR/DWR RECEIVED				
NOV 14 2002				
LAS VEGAS OFFICE				

8. WELL CONSTRUCTION
 Depth Drilled 618 Feet Depth Cased 618 Feet
 HOLE DIAMETER (BIT SIZE)
14.5 Inches From 0 Feet To 618 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8.625</u>	<u>16.94</u>	<u>.188</u>	<u>0</u>	<u>618</u>

Perforations:
 Type perforation STAINLESS STEEL SCREEN
 Size perforation 1/16
 From 497 feet to 597 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 240 feet to 618 feet

9. WATER LEVEL
 Static water level 140 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name GREAT BASIN DRILLING CO. OF NEVADA, INC. Contractor
 Address P.O. BOX 4220 Contractor
PAHRUMP, NV. 89048
 Nevada contractor's license number issued by the State Contractor's Board 47333
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dean
 By driller performing actual drilling on-site of contractor
 Date 10/31/02

Date started 10/21/2002 .19
 Date completed 10/30/2002 .19

7. WELL TEST DATA

TEST METHOD:	Draw Down (Feet Below Static)			Time (Hours)
	G.P.M.	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pump	