WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 87202
Permit No.
Basin 162

NOTICE OF INTENT NO. 24168

1. OWNER James Fulton
MAILING ADDRESS
ADDRESS AT WELL LOCATION 5141 N. Michelle Ave.

2. LOCATION SE ¼ SE ¼ Sec. 16 T 19-S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 29-281-14 (Parcel No.) The Country Place II Ut:3 Bk:23 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Sandy Loam | | 0 | 30 | 30 |
| BrownClay/Caliche | | 30 | 62 | 32 |
| BrownClay | X | 62 | 128 | 66 |
| BrownClay/Caliche | X | 128 | 172 | 44 |
| BrownClay | X | 172 | 240 | 68 |

DCNR/DWR
RECEIVED
NOV 22 2002
LAS VEGAS OFFICE

Date started November 5, 2002
Date completed November 5, 2002, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 4 | ¼ |

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 12 Inches | 0 Feet | 240 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | 0 | 240 |

Perforations:
Type perforation Torch Cut
Size perforation ¼" width 8" long
From 200 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 89 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) JIM PIKE WELL DRILLING, LLC.
Address (Contractor) P.O. BOX 56
PAHRUMP, NV. *89041
Nevada contractor's license number issued by the State Contractor's Board 17563A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
Signed (By driller performing actual drilling on site or contractor)
Date November 19, 2002

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627