WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84252
Permit No.
Basin 107

NOTICE OF INTENT NO. 48339

1. OWNER Craig Uhland Const
MAILING ADDRESS PO Box 237 Wellington, Nev 89444
ADDRESS AT WELL LOCATION 52 Upper Colony Rd Wellington, NV 89444

2. LOCATION SE ¼ NW ¼ Sec. 34 T. 11 N/S R. 23 E/W Lyon County
PERMIT NO. Issued by Water Resources
Parcel No. 10-351-21
Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown + White D.G.		0	5	5
Brown Clay		5	8	3
Brown + White D.G. + Sand		8	45	37
Brown Clay		45	52	7
Brown + White D.G. Gravel		52	90	38
Brown Clay		90	96	6
Brown + White D.G. + Gravel		96	115	19
Brown Clay		115	130	15
Sand + Gravel		130	140	10
Brown Clay		140	160	20
Brown + White, Green Red D.G. Gravel		160	200	40

Date started 6-24-02, 20
Date completed 6-25-02, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		2

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12.5	0	200

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.5		.188	0	200

Perforations:
Type perforation Factory
Size perforation
From 150 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 200 feet to 100 feet

9. WATER LEVEL
Static water level 40 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nevada Pump + Drilling Contractor
Address PO Box 2227 Contractor
Dayton NV 89403
Nevada contractor's license number issued by the State Contractor's Board 0046357
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2157
Signed Thomas Evans By driller performing actual drilling on site or contractor
Date 6-27-02

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 12-01) (O)-627