FOR 8 WELLS
WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87313
Permit No.
Basin 212

NOTICE OF INTENT NO 22555

1. OWNER Wynn Las Vegas LLC
MAILING ADDRESS 3145 Las Vegas Blvd. South
Las Vegas, NV. 89109-1929

ADDRESS AT WELL LOCATION 3131 Las Vegas Blvd. South
Las Vegas, NV. 89109

2. LOCATION NE ¼ NW ¼ Sec. 16 T. 21S N/S R. 61 E. Clark County
PERMIT NO. DW 1152 (Issued by Water Resources) 162-16-113-005 (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other dewatering

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test Dewatering
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Cemented Calieche		0	13	
Brown Clay		13	15	
Cemented Calieche		15	16	
Brown Clay w/ Stringers of gravel		16	35	
Calieche		35	36	
Brown Clay		36	40	

Date started December 13, 2002 XXX
Date completed December 24, 2002 XXXX

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 40 Feet Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12-1/4 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6518			+3	40
PVC				

Perforations:
Type perforation Screen PVC
Size perforation
From 20 feet to 40 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 15
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout X Bentanite

Gravel Packed: ☒ Yes ☐ No
From 15 feet to 40 feet

9. WATER LEVEL
Static water level 5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Thompson Drilling Co., Inc. (Contractor)
Address 7227 Hauck St. (Contractor)
Las Vegas, NV. 89118
Nevada contractor's license number issued by the State Contractor's Board 4286A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2074
Signed Richard K. Thompson (By driller performing actual drilling on site or contractor)
Date January 7, 2003

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627