WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 873162
Permit No. 68484
Basin 212

NOTICE OF INTENT NO. 24121

1. OWNER Paul & Nancy Szymanski
MAILING ADDRESS Same

ADDRESS AT WELL LOCATION 7725 N. Rainbow Blvd.
Las Vegas, Nev.

2. LOCATION SW ¼ NW ¼ Sec. 14 T. 19S N/S R. 60 E. Clark County
PERMIT NO. 68484 (Issued by Water Resources) | 125-14-201-006 (Parcel No.) | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	18	
Yellow Clay & Gravel		18	26	
Clay		26	105	
Caliche		105	116	
Clay		116	390	
Caliche & Water	xx	390	450	
Clay		450	550	
Reddish Rock & Water	xcc	550	610	
Clay		610	640	
Reddish Rock Water	xxx	640	670	

DCNR/DWR
RECEIVED
NOV 13 2002
LAS VEGAS OFFICE

Date started 11/7/02, 20
Date completed 11/13/02, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 670 Feet Depth Cased 670 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12 1/4	0	55
10	55	670

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+2	57
6 1/2	SDR PVC		+1	670

Perforations:
Type perforation Factory
Size perforation .032 Sieve Type
From 613 feet to 670 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 139 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick (Contractor)
Address 5360 Bonita Vista St. (Contractor)
Las Vegas, Nev. 89149

Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed V H Dimick (By driller performing actual drilling on site or contractor)
Date 11-13-02

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627