

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 87376
 Permit No. _____
 Basin 212

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 21125

1. OWNER SOUTHERN NEVADA WATER AUTHORITY ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1900 E. FLAMINGO RD. SUITE 170
LAS VEGAS, NEVADA 89119

2. LOCATION NW 1/4 SW 29 T. 21 N. R. 63 E. CLARK County
 PERMIT NO. DW 1151 Issued by Water Resources Parcel No. 160-2-301-001 Subdivision Name NA

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Municipal/Industrial Irrigation Monitor Test Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other BUCKET

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>24 WELLS</u>				
<u>SILT</u>		<u>0</u>	<u>8</u>	<u>8</u>
<u>CLAY</u>		<u>8</u>	<u>14</u>	<u>6</u>
<u>COARSE SAND w/ GRAVEL</u>		<u>14</u>	<u>28</u>	<u>14</u>
<u>CAULICHE / REFUSAL</u>		<u>28</u>	<u>?</u>	

8. WELL CONSTRUCTION
 Depth Drilled 28 Feet Depth Cased 28 Feet

HOLE DIAMETER (BIT SIZE)
 From 36 Inches To 0 Feet 28 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>12"</u>	<u>15</u>	<u>.250</u>	<u>0</u>	<u>28</u>

Perforations:
 Type perforation LOUVERED
 Size perforation .040

From 8 feet to 16 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 10' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 9-16-02, 19____
 Date completed 11-22-02, 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 8 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name KELLEY DEWATERING & CONSTRUCTION CO. Contractor
 Address 5175 CLAY AVE. Contractor
WYOMING, MICHIGAN 49548
 Nevada contractor's license number issued by the State Contractor's Board 50826
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller ABDS 2149
 Signed [Signature] By driller performing actual drilling on site or contractor
 Date 12-2-02