WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 87390
Permit No.
Basin 212

NOTICE OF INTENT NO. 23121

1. OWNER: Shea Prof Plaza Invest LLC
MAILING ADDRESS: 8940 Raintree Dr #200, Scottsdale, AZ 85260
ADDRESS AT WELL LOCATION: 2650 S. Jones Blvd, Las Vegas, NV

2. LOCATION: N ¼ NW ¼ Sec. 12 T. 21 N/S R. 60 E. CLARK County
PERMIT NO. (Issued by Water Resources) 163-12-104-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Abandon 1-well | | | | |
| 8 5/8" casing | | | | |
| 157' deep | | | | |
| Static water level 88' | | | | |
| Perforate from 155' to 50' | | | | |
| Trimmie 4 yards of slurry | | | | |

Date started 12/17/02, 20
Date completed 12/17/02, 20

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| Inches | Feet | Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| | | | | |
| | | | | |
| | | | | |

Perforations:
Type perforation
Size perforation
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor): ALLEN DRILLING INC.
Address (Contractor): 4847 S. VALLEY VIEW, LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board: 18917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller: 1301
Signed: Fred R. Allen III
By driller performing actual drilling on site or contractor
Date 1/15/03

(Rev. 12-01) USE ADDITIONAL SHEETS IF NECESSARY (O)-627