

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

*2 wells*

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20293

1. OWNER Michael Costanza ADDRESS AT WELL LOCATION 1132 W. Bonanza Rd. Las Vegas, NV  
 MAILING ADDRESS Route 10 Green Hills P.O. Box 7635 Reading, PA 19603  
 2. LOCATION NW 1/4 SE 1/4 Sec. 28 T 20 N/S R. 61 E Clark County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources 139-28-703-004 Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other HSA

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt		0	4"	4"
Type II		4"	82"	8"
Silty Sand w/gravel		1	7	6
Silty Clay w/gravel		7	12	5
caliche		12	14	2
silty sand w/gravel		14	17	3
silty sand		17	19	2
caliche		19	20	1
silty sand w/gravel		20	22	2
clay		22	25	3

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 11 Inches To 0 Feet 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.50</u>		<u>Sch 40 PVC</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation Machine - 5/8 H-80  
 Size perforation .020  
 From 5 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 3  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 3 feet to 25 feet

Date started 12/04/03, 2003  
 Date completed 12/04/03, 2003

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 17 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 64.1 °F Quality Contaminated

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Eagle Drilling Services Contractor  
 Address 2150 Placid Las Vegas, NV 89119 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 51266  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193  
 Signed Victor Shaw  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_