

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20289

1. OWNER County of Clark (Aviation) ADDRESS AT WELL LOCATION 6591 S. Spencer
 MAILING ADDRESS P.O. Box 11005 Las Vegas, NV
Las Vegas, NV 89111

2. LOCATION NE 1/4 NW 1/4 Sec. 02 T. 22 N/S R. 61 E Clark County
 PERMIT NO. 177-02-102-018 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Removed 160' of 4" PVC Certilock casing from Well				
Milled out well to a depth of 165'				
Perforated Casing 4 times every foot from Perforation size was 3" long by 7/8" wide				
Pumped 24 sack neat cement from bottom of well in an upward direction using tremie hose consisting of 2" x 0.059 Code SF-10 hose to the top of the well				
Neat Cement was delivered by Rinker Mat.				
Neat Cement was Pumped by Brecock Pumping				

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)
 From _____ To _____
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 09/24 LAS VEGAS OFFICE, 2002
 Date completed 09/26, 2002

9. WATER LEVEL

Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 60.1 °F Quality Clear

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Eagle Drilling Services Contractor
 Address 7150 Placid Las Vegas, NV
89119 Contractor

Nevada contractor's license number issued by the State Contractor's Board 51266
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2193

Signed Victor Cline
 By driller performing actual drilling on site or contractor
 Date 10/08/02