

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21230

1. OWNER Nellis AFB ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 79 1/2 Cst/Car. Envt. Control Management Nellis AFB Nev. 89191 _____
 2. LOCATION NE 1/4 NE 1/4 Sec. 4 T. 20 N/S R. 62 E. Clark County
 PERMIT NO. 140-04-502-002 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Sand Gravel Silt, Clay</u>		<u>0</u>	<u>15</u>	<u>15</u>
<u>Silt + Clay</u>		<u>15</u>	<u>25</u>	<u>10</u>
<u>Coarsened Gravel</u>		<u>25</u>	<u>30</u>	<u>5</u>
<u>Silt + Clay</u>		<u>30</u>	<u>65</u>	<u>35</u>
<u>Gravel</u>		<u>65</u>	<u>70</u>	<u>5</u>
<u>Silt + Clay Gravel stringers</u>		<u>70</u>	<u>90</u>	<u>20</u>

8. WELL CONSTRUCTION
 Depth Drilled _____ Feet Depth Cased _____ Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 90
12 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>	<u>PVC</u>		<u>30</u>	<u>90</u>
<u>6</u>		<u>.183</u>	<u>90</u>	<u>90</u>

Perforations:
 Type perforation Endless Rap & Screen
 Size perforation 5/20
 From 60 feet to 90 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 90 feet to 58 feet

9. WATER LEVEL
 Static water level 70 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 78 °F Quality Bad

Date started Aug 20 2002
 Date completed Aug 20 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>3</u>	<u>1 hr.</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Water Development Corp Contractor
 Address 500 Main St Woodland CA 95695 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0012852
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 20217
 Signed Michael D Wells
 By driller performing actual drilling on site or contractor
 Date Dec 29, 2002