

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 22018

1. OWNER Phil Norgren ADDRESS AT WELL LOCATION 413 W. Bonanza Road  
 MAILING ADDRESS 26 Penfield Place Las Vegas NV 89101  
Bridgeport CT 06605-3422

2. LOCATION SE 1/4 SW 1/4 Sec 27 T 20 S R 61 E County Clark

PERMIT NO \_\_\_\_\_ Issued by Water Resources \_\_\_\_\_ Parcel No. 139-27-410-026 Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt parking lot		0	1"	1"
Silt w/ clay		1"	4"	3'11"
Clay w/ silt		4'	8'	4'
Silty clay		8'	10'	2'
Silty clay w/ gravel and caliche		10'	17'	7'
Silty clay w/ caliche		17'	20'	3'
Clay w/ silt and caliche		20'	27'	7'
Clay w/ silt and gravel		27'	31'	4'

8. WELL CONSTRUCTION

Depth Drilled 31 Feet Depth Cased 31 Feet

HOLE DIAMETER (BIT SIZE)

Inches	Feet	To
<u>6</u>	<u>0</u>	<u>31</u>
_____	_____	_____
_____	_____	_____

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>		<u>.308</u>	<u>0</u>	<u>31</u>

Perforations:  
 Type perforation Factory slot PVC  
 Size perforation 0.020

From 21 feet to 31 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 4.5 ft.  Neat Cement  
 Placement Method  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 19 feet to 31 feet

RECEIVED  
 JAN 30 2003  
 LAS VEGAS OFFICE

9. WATER LEVEL

Static water level 25.5 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started August 9, 2002  
 Date completed August 9, 2002

7. WELL TEST DATA

TEST METHOD	<input type="checkbox"/> Bailer	<input type="checkbox"/> Pumped	<input type="checkbox"/> Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

10. DRILLER'S CERTIFICATE

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Converse Consultants Contractor  
 Address 731 Pilot Road, Ste. H., Las Vegas NV 89119 Contractor

Nevada contractor's license number  
 Issued by the State Contractor's Board 48947  
 Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller M 1589

Signed Ronald J. [Signature]  
 By driller performing actual drilling on-site or contractor

Date 1/29/03