


STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 22021

1. OWNER Maryland Square Shopping Center, LLC ADDRESS AT WELL LOCATION 3528 S. Maryland Parkway  
 MAILING ADDRESS 777 N. Rainbow Blvd. Las Vegas NV  
 Las Vegas NV  
 2. LOCATION SW 1/4 NW 1/4 Sec 14 T 21 SR 61 E County Clark  
 PERMIT NO 162-14-213-002  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. (MW-7) LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand		0'	4.5'	4.5'
Fine sand		4.5'	7.5'	3.0'
Sand		7.5'	10.5'	3.0'
Caliche		10.5'	12.5'	2.0'
Sand		12.5'	13.5'	1.0'
Fine sand		13.5'	14.5'	1.0'
Caliche		14.5'	15.5'	1.0'
Sand		15.5'	19.5'	4.0'
Sand w/ some clay		19.5'	20.5'	1.0'
Silty clay		20.5'	22.5'	2.0'
Clay		22.5'	30.0'	7.5'

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To 0 Feet 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375		0.308	0	30

Perforations:  
 Type perforation Factory slot PVC  
 Size perforation 0.020"  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 2 ft.  Neat Cement  
 Placement Method  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 8 feet to 30 feet

9. WATER LEVEL  
 Static water level 20 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATE  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Date started September 19, 2002  
 Date completed September 19, 2002

7. WELL TEST DATA

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pumped <input type="checkbox"/> Air Lift			

Name Converse Consultants Contractor  
 Address 731 Pilot Road, Ste. H., Las Vegas NV 89119 Contractor  
 Nevada contractor's license number  
 Issued by the State Contractor's Board 48947  
 Nevada driller's license number issued by the  
 Division of Water Resources, the on-site driller M 1589  
 Signed *Ronald J. [Signature]*  
 By driller performing actual drilling on-site or contractor  
 Date 1/29/03

RECEIVED  
 JAN 30 2003  
 LAS VEGAS OFFICE