WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87647
Permit No.
Basin 101

NOTICE OF INTENT NO. 20300

1. OWNER Cobas Construction (Kietty) ADDRESS AT WELL LOCATION 5091 Sandalwood
MAILING ADDRESS

2. LOCATION SE ¼ SE ¼ Sec. 29 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 08-651-72 (Parcel No.) Copperwood - (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
top Soil		0	4	4
Sandy Clay	X	4	16	12
Clay Brown		16	23	7
Silty Sand	X	23	37	14
Black Clay	X	37	44	7
Black Silt	X	44	85	41
Grey Clay	X	85	98	13
Yellow Sand	X	98	112	14
Grey Clay	X	112	116	4
Grey Gravel	X	116	150	34
Brown Sand	X	150	167	17

STATE ENGINEER'S OFFICE
JAN - 7 1993

Date started Nov 18, 19 92
Date completed Nov 19, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30 +		1

8. WELL CONSTRUCTION
Depth Drilled 167 Feet Depth Cased 167 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10	Inches	0	Feet	50	Feet
6	Inches	50	Feet	167	Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+1	167

Perforations:
Type perforation Machine Slot
Size perforation 50 thou
From 165 feet to 164 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 12-6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature 57 °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Welco Corp (Contractor)
Address Box 888 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 11752
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772
Signed (By driller performing actual drilling on site or contractor)
Date Nov 23 - 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627