

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 87921
 Permit No. 0981
 Basin 1

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 2112

1. OWNER Bob Hendrix ADDRESS AT WELL LOCATION 529 Sunrise Loop
 MAILING ADDRESS 2100 Mt View Drive

2. LOCATION NW 1/4 SE 1/4 Sec 6 T. 2918 N/S R. 1879 E Churchill County
 PERMIT NO. _____ Parcel No. _____ Subdivision Name Hendrix Estates

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown Sand		0	25	25
Brown Clay/Sand	x	25	35	10
Black Sand	x	35	67	32
Black Clay		67	75	8
Grey Sand	x	75	85	10
Grey Clay		85	96	11
Brown Sand	x	96	98	2
Sand & Gravel	x	98	112	14

8. WELL CONSTRUCTION

Depth Drilled 112 Feet Depth Cased 112 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To	Feet	Feet
<u>10</u>	<u>0</u>	<u>50</u>		
<u>6</u>	<u>50</u>	<u>112</u>		

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>10.9</u>	<u>.188</u>	<u>71</u>	<u>112</u>

Perforations:
 Type perforation Machine slot
 Size perforation .0050

From _____ feet to _____ feet
 From 106 feet to 110 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From _____ feet to _____ feet

9. (WATER LEVEL)
 Static water level 8-9' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature 59 °F Quality Un-tested

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Welsco Contractor
 Address Box 888 Contractor

Nevada contractor's license number issued by the State Contractor's Board 11752
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 772

Signed W. Billie
 By drilled performing actual drilling on site or contractor
 Date 12-8-92

Date started Dec 3, 1992
 Date completed Dec 3, 1992

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>		<u>1 hr</u>

RECEIVED
 JAN - 7 1993
 STATE ENGINEER'S OFFICE