WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 84785
Permit No.
Basin 212

NOTICE OF INTENT NO. 23520

1. OWNER Pat L. Santagelo
MAILING ADDRESS HCR 38 #194
Mt. Charleston NV. 89124

ADDRESS AT WELL LOCATION Same
14050 Rustic Rd.

2. LOCATION SE ¼ NW ¼ Sec. 6 T. 19 N/S R. 59 E. Clark County
PERMIT NO. (Issued by Water Resources) 126-06-201-006 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel - W/Sandy Clay		0	215	215
Brown Clay W-Gravel		215	285	70
Cemented Gravel		285	305	20
Grey Lime Stone		305	316	11
Clay Gravel Boulders		316	365	49
Red Clay - Gravel		365	400	35
Brown Clay Gravel	✓	400	475	75
Red Sand Stone	✓	475	500	25

RECEIVED
FEB 18 2003
LAS VEGAS OFFICE

Date started 1-24-03, 19
Date completed 1-27-03, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35		2 HRS.

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 495 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	500 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 IN.	F480	PVC	+1	495
5 Ft.	188	8 5/8		

Perforations:
Type perforation Saw
Size perforation 1/8 - 12
From 395 feet to 495 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 352 feet below land surface
Artesian flow G.P.M. B.I.
Water temperature Cool °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Redding Drilling (Contractor)
Address 3955 Blue Diamond Rd #d (Contractor)
Las Vegas, NV. 89139
Nevada contractor's license number issued by the State Contractor's Board 38155
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1617
Signed Floyd Spitzel (By driller performing actual drilling on site or contractor)
Date 1-27-03

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627