


STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 81900
 Permit No. _____
 Basin 083



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 50397

1. OWNER Operating Engineers ADDRESS AT WELL LOCATION North of I-80, painted Rock Rest
 MAILING ADDRESS 1200 Corporate Blvd Reno, NV 89502 Area _____
 2. LOCATION NW 1/4 NE 1/4 Sec. 13 T 20N N/S R 23E E _____ Washoe County
 PERMIT NO. waiver W-540/68663 084-281-04 Subdivision Name _____
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand		0	40	
clay		40	80	40
rock/gray & red		80	320	240
red volcanic & clay		320	370	50
gray/green rock	X	370	400	30
gray/green w/red rock		400	490	90
fault line	X	490	495	5
gray/green rock		495	580	85
fault line/sand	X	580	583	3
gray /green rock		583	620	37

8. WELL CONSTRUCTION
 Depth Drilled 620 Feet Depth Cased 596 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
17 inches	0 Feet	100 Feet
12-1/8 inches	100 Feet	620 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Well Thickness (Inches)	From (Feet)	To (Feet)
8-5/8		.250	+1	596
12		.250	0	100

Perforations:
 Type perforation mill slot
 Size perforation 1/8 x 3

From	To
296 feet	596 feet
_____ feet	_____ feet
_____ feet	_____ feet
_____ feet	_____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 100

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 100 feet to 600 feet

9. WATER LEVEL
 Static water level 325 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address 4675 W. Winnemucca Blvd Contractor
Winnemucca, Nevada 89445
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1713 & 1154 T-1
 Signed [Signature]
 by driller performing actual drilling on-site or contractor
 Date 9-1-02

Date started 6/5/02, 19__
 Date completed 8/16/02, 19__

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>P/L 468</u>	<u>100</u>	<u>143</u>	<u>23 hrs.</u>

RECEIVED
 02 SEP - 4 AM 10: 10
 STATE ENGINEERS OFFICE