WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 87933
Permit No.
Basin 106

NOTICE OF INTENT NO. 47254

1. OWNER B D R Construction Tom Tran
MAILING ADDRESS Wellington,, NV 89444
ADDRESS AT WELL LOCATION 3641 Quail Run Rd. Topaz Nv.

2. LOCATION SW 1/4 SW 1/4 Sec. 16 T 10N N/S R 22E E Douglas County
PERMIT NO. Issued by Water Resources
1022-16-002-087 Parcel No.
Quail Run Subdivision Name

3. **WORK PERFORMED**
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. **PROPOSED USE**
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. **WELL TYPE**
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other mud

6. **LITHOLOGIC LOG**

Material	Water Strata	From	To	Thickness
clay soil	no	0	4	4
sand and smal gravel	no	4	68	64
sandy clay	no	68	73	5
sand and med. gravel	yes	73	140	67

8. **WELL CONSTRUCTION**
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	140	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	0	140

Perforations:
Type perforation factory milled
Size perforation 1/8 X3 6 row
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. **WATER LEVEL**
Static water level 23 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

Date started 4/22/2002, 19
Date completed 4/25/2002, 19

7. **WELL TEST DATA**
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		1hr

10. **DRILLER'S CERTIFICATION**
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Eddco Exploration Inc Contractor
Address 7780 Curry Rd. Contractor
Fallon,Nv, 89406
Nevada contractor's license number issued by the State Contractor's Board 27673A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1586
Signed By driller performing actual drilling on-site or contractor
Date 5/4/2002

USE ADDITIONAL SHEETS IF NECESSARY