

**WELL DRILLER'S REPORT**

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.300

NOTICE OF INTENT NO. **46577**

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER **KOPAS KONSTRUCTION** ADDRESS AT WELL LOCATION **1022 VENTURACCI LANE**  
 MAILING ADDRESS **P. O. BOX 5024**  
**FALLON, NV 89406**

2. LOCATION **NW 1/4 SE 1/4 Sec. 24 T 19 N/S R 28 E** **CHURCHILL** County  
 PERMIT NO. **08-314-50** **VENTURACCI** Subdivision Name  
Issued by Water Resources Parcel No.

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	1	1
BROWN SAND		1	18	17
BROWN CLAY		18	20	2
BROWN SAND		20	40	20
GREY SAND		40	70	30
GREY CLAY		70	80	10
BROWN SAND		80	90	10
BROWN CLAY		90	93	3
GREY SAND		93	120	27
BLACK SILT/CLAY		120	170	50
GREY SAND		170	210	40
GREY CLAY		210	212	2
BROWN SAND	X	212	224	12

8. WELL CONSTRUCTION  
 Depth Drilled **224** Feet Depth Cased **224** Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0	100
6 5/8 Inches	100	224

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	+2	224

Perforations:  
 Type perforation **MILL SLOT**  
 Size perforation **.080**

From	To
218 feet to	222 feet
feet to	feet
feet to	feet
feet to	feet
feet to	feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal **100'**  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
 Water temperature **COOL** °F Quality **UNTESTED**

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name **WELSCO CORP.** Contractor  
 Address **P. O. BOX 888** Contractor  
**FALLON, NV 89406**

Nevada contractor's license number issued by the State Contractor's Board **772 / 1752**  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **2199**

Signed *[Signature]*  
 By driller performing actual drilling on-site or contractor

Date **4/2/2002**

Date started **2/14/2002**, 19  
 Date completed **3/19/2002**, 19

7. WELL TEST DATA

TEST METHOD:	TEST METHOD:		Time (Hours)
	G.P.M.	Draw Down (Feet Below Static)	
<b>AIR BLOWN</b>	<b>25</b>		<b>1 HR</b>

Bailer  Pump  Air Lift