WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88001
Permit No.
Basin 101

NOTICE OF INTENT NO. 44558

1. OWNER Edward Knecht
MAILING ADDRESS
ADDRESS AT WELL LOCATION 6665 Sietta Way Fallon, Nevada

2. LOCATION SE ¼ SW ¼ Sec. 18 T. 19 N/S R. 28 E. Churchill County
PERMIT NO. (Issued by Water Resources) 08-112-36 (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	14	
Gravel Clay		14	20	
Clay		20	33	
Sand Gravel some Clay		33	120	
Clay Gray		120	156	
Sand Gravel		156	189	
Clay		189	207	
Sand Gravel		207	241	
Clay		241	257	
Gravel / Sand		257	276	
Clay		276	284	
Gravel		284	309	
Sand		309	360	
Clay		360	405	
Sand Coarse		405	440	

RECEIVED 02 APR 22 AM 10:40 STATE ENGINEER'S OFFICE

Date started 3-25, 2002
Date completed 3-29, 2002

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
About	300 to 400		

8. WELL CONSTRUCTION
Depth Drilled 440 Feet Depth Cased 440 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0 Feet	440 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	19.00	3/16	+1	440

Perforations:
Type perforation mill slot
Size perforation 3/16 x 4 Long
From 400 feet to 440 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 440 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature]
By driller performing actual drilling on site or contractor
Date 3-29-02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627