WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88051
Permit No.
Basin 33A
NOTICE OF INTENT NO. 34851

1. OWNER Don Brandt
MAILING ADDRESS 203 11th Ave. South, Nampa, Id 83651
ADDRESS AT WELL LOCATION N/A

2. LOCATION SW ¼ NE ¼ Sec. 28 T. 43 N/S R. 37 E. Humboldt County
PERMIT NO. Ext 4935/16702 (Issued by Water Resources) — (Parcel No.) N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☒ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel w/s Clay		0	30	
Cemented Gravel		30	60	
Cemented Rock w/s clay		60	70	
Cemented Gravel		70	80	
Clay w/ Cemented gravel		80	90	
Clay w/ gravel		90	100	
Clay		100	110	
Clay w/s pea gravel		110	165	
Cemented gravel w/very little Clay		165	175	
Cemented Rock		175	185	
Clay		185	195	
Clay w/s gravel		195	210	
Clay		210	220	
Clay w/ little gravel		220	250	
Cemented Rock & gravel		250	260	
Clay		260	310	
Clay w/very little pea gravel		310	335	
Pea Gravel		335	345	
Gravel & Rock		345	360	
Gravel		360	370	
Gravel w/streaks of Clay		370	380	
Gravel		380	390	
Rock & Gravel		390	400	
Sandy Clay		400	450	
Rock & Clay		450	545	
Gravel		545	605	

Date started 02-02, 1902
Date completed 02-26-02, 1902

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☒ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
2100	119	8.5
~~1300~~	~~[illegible]~~	~~[illegible]~~
2000	116	3.5
1800	106	11

8. WELL CONSTRUCTION
Depth Drilled 605 Feet Depth Cased 595 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
28 Inches		0 Feet	605 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	+1	595

Perforations:
Type perforation Sawed
Size perforation ¼ x 3
From 130 feet to 595 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 55' feet to 595 feet

9. WATER LEVEL
Static water level 106 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling (Contractor)
Address 3040 Calkahan Street (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 3-8-02

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627