



Log No. 88081  
 Permit No. \_\_\_\_\_  
 Basin 105

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 48335

1. OWNER Frank Scharo Construction ADDRESS AT WELL LOCATION 2020 Rocking Horse  
 MAILING ADDRESS PO Box 1225 Minden NV 89423 Gardnerville NV 89410  
 2. LOCATION SE 1/4 NW 1/4 Sec. 19 T. 12 S R. 21 E Douglas County  
 PERMIT NO. 1221-19-001-012 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
BROWN SAND		0	8	8
Red CLAY		8	10	2
SAND+GRAVEL		10	50	40
BROWN CLAY+GRAVEL		50	60	10
BROWN CLAY		60	92	32
BROWN CLAY+SAND		92	108	16
BROWN CLAY		108	125	17
BROWN CLAY+GRAVEL		125	130	5
BROWN CLAY+SAND		130	140	10
SAND+GRAVEL		140	148	8
BROWN CLAY		148	160	12
BROWN CLAY+SAND+GRAVEL		160	185	25
SAND+GRAVEL		185	200	15
BROWN CLAY+SAND		200	220	20
BROWN CLAY		220	230	10
BLACK BROWN, Red, WHITE, Grey Rock	✓	230	300	70

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
10 3/8 Inches From 0 Feet To 300 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>.188</u>	<u>0</u>	<u>300</u>

Perforations:  
 Type perforation FACTORY  
 Size perforation \_\_\_\_\_  
 From 260 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 30'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 300 feet to 50 feet

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name NEVADA PUMP & DRILLING  
 Address P.O. BOX 2227 DAYTON, NV 89403  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2187  
 Signed Thomas Evans  
 By driller performing actual drilling on site or contractor  
 Date 5-29-02

Date started 5-11-02, 20  
 Date completed 5-12-02, 20

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>30-40</u>		<u>2</u>

RECEIVED  
 02 JUL - 1 PM 12:53  
 STATE ENGINEERING OFFICE