

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 34852

1. OWNER Verna M Barrows ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS HCCI Box 20
Battle Mountain, NV 89820
 2. LOCATION NW 1/4 NE 20 T. 34 N/S R. 45 E ~~Humboldt~~ County
 PERMIT NO. 68404T Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	15	
Sandy Clay & Gravel		15	25	
Sandstone		25	40	
Sandy Clay		40	55	
Gray Clay		55	90	
Blue Clay		90	115	
Green Clay		115	150	
Sandy Clay		150	210	
Sandstone & clay		210	250	
Sandy clay		250	280	
Sandstone & clay		280	310	
Brown Clay		310	350	
Clay & coarse sand		350	390	
Clay & sandstone		390	400	
Clay & coarse sand		400	410	
Clay & sandstone		410	430	
Clay & Gravel		430	440	
Clay & sand		440	480	

8. WELL CONSTRUCTION
 Depth Drilled 480 Feet Depth Cased 480 Feet
 HOLE DIAMETER (BIT SIZE)
 From _____ To _____
28 Inches _____ Feet 48 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16		.250	±1	160

Perforations:
 Type perforation Saw cut
 Size perforation 3/16 Double perf
 From 160 feet to 480 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 55 Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 55 feet to 480 feet

9. WATER LEVEL
 Static water level 165 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COOL °F Quality Good

Date started 5-15 2002
 Date completed 5-20 2002

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name American Drilling & Pump Service Contractor
 Address 3040 Callahan Street Contractor
Winnemucca, NV 89445
 Nevada contractor's license number issued by the State Contractor's Board 0020578
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 2208
 Signed Owen Bunkerhoff
 By driller performing actual drilling on site or contractor
 Date 7-14-02