WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 88093
Permit No.
Basin 099

NOTICE OF INTENT NO. 44319

1. OWNER Don Messmer
MAILING ADDRESS 200 Appaloosa Cir Reno NV 89506
ADDRESS AT WELL LOCATION 200 Appaloosa Cir. Reno NV 89506

2. LOCATION NE ¼ NW ¼ Sec. 9 T. 23 N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 078-221-10 (Parcel No.) Rancho Haven (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	5	5
Clay		5	15	10
Sand		15	60	45
DG		60	223	163
DG Fract.		223	230	7
DG Hard		230	295	65
DG Fract		295	412	117

RECEIVED 02 APR 16 AM 10:56 STATE ENGINEER'S OFFICE

Date started 3/11/02
Date completed 3/25/02

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15	280'	6

8. WELL CONSTRUCTION
Depth Drilled 412 Feet Depth Cased 412 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	180 Feet
8 1/4 Inches		180 Feet	412 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.89	188	2+	412

Perforations:
Type perforation Saw slot
Size perforation 060 Ins.
From 412 feet to 392 feet
From 372 feet to 352 feet
From 332 feet to 292 feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 412 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature NA °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Olenski Drilling & Pump Co. (Contractor)
Address 15045 Red Rock Rd (Contractor)
Reno NV 89506
Nevada contractor's license number issued by the State Contractor's Board 50343
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1656
Signed John F Olenski (By driller performing actual drilling on site or contractor)
Date 4/9/02

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627