

WHITE-DIVISION OF WATER RESOURCES  
CANARY-CLIENTS COPY  
PINK-WELL DRILLER'S COPY

STATE OF NEVADA  
DIVISION OF WATER RESOURCES

### WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY  
Log No. **28098**  
Permit No. **212**  
Basin: **46083**

NOTICE OF INTENT NO. **46083**

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

1. OWNER/Kindred Maxyan Energy Partners  
MAILING ADDRESS 5049 N Sloan Lane  
Las Vegas NV 89115

ADDRESS AT WELL LOCATION  
4915 N Sloan Lane  
Las Vegas NV 89115

2. LOCATION SE 1/4 SE 1/4 Sec 33 T 19 N 8 R 62 E County Clark

PERMIT NO. 123-33-801-004 Parcel No.

Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4.  Domestic  Municipal/Industrial  
 Irrigation  Test  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Other  SEAL

### 6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>1# Brown Sand/Clay</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Sandy Clay small pebbles</u>		<u>10</u>	<u>40</u>	<u>30</u>
<u>Silty Clay Ls Brown</u>		<u>40</u>	<u>90</u>	<u>50</u>
<u>Brown clay</u>	<u>SS</u>	<u>90</u>	<u>135</u>	<u>45</u>

8. WELL CONSTRUCTION  
Depth Drilled 135 Feet Depth Cased 135 Feet

### HOLE DIAMETER (BIT SIZE)

9 Inches From 0 Feet To 135 Feet  
4" Inches From 0 Feet To 135 Feet

### CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4"</u>		<u>5/16</u>	<u>0</u>	<u>80</u>
<u>4"</u>		<u>5/16</u>	<u>40</u>	<u>130</u>

### Perforations:

Type perforation Factory  
Size perforation 020 / 010  
From 80 feet to 110 feet (020)  
From 130 feet to 135 feet (010)  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  Cement Grout  Concrete Grout  
Depth of Seal 78  
Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
From 78' - 112' feet to 129' - 135' feet

### 9. WATER LEVEL

Static water level \_\_\_\_\_ feet below land surface  
Artesian flow \_\_\_\_\_ G.P.M. P.S.I.  
Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

### 10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Baact Longyee Contractor  
Address Po Box 1000 Contractor 89403

Nevada contractor's license number 00219716 (10157)  
issued by the State Contractor's Board 00219716

Nevada driller's license number issued by the Division of Water Resources, the on site driller M-2222

Signed Anna Anderson  
By driller performing actual drilling on site or contractor  
Date 10-21-02

Date started 10-12-02 10:20am  
Date completed 10-14-02 10:20am

### 7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift  
G.P.M. Draw Down (Feet Below Static) Time (Hours)