WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 8812
Permit No. 29756
Basin 104

NOTICE OF INTENT NO. 42234

1. OWNER Carson City, Fuji Park
MAILING ADDRESS 3505 Butti Way
Carson City, NV 89701

ADDRESS AT WELL LOCATION 701 Clear Creek Rd.
Carson City, NV.

2. LOCATION SW 1/4 SE 1/4 Sec. 31 T 15N N/S R 20E E Carson City County
PERMIT NO. 29756/65876 Issued by Water Resources
09-303-02 Parcel No.
Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Measured static water level at 20.13'. Measured depth of well at 152'. Removed 105' of drop pipe and 2hp submersible pump from well. Bailed well to a depth of 153' and hit hard bottom. Installed 6" mills knife and perforated from 126' to 50' with 4 rows per foot. Installed 147' of 2" tremme pipe and pumped in approximately 2 cubic yards of neat cement. Well volume should have required 29 cubic feet. Excavated around casing and cut casing off 2' below ground level.				

PoA of log 15856

Date started 11/15/2002, 19__
Date completed 11/15/2002, 19__

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"		.250"	+1	155

Perforations:
Type perforation mills knife
Size perforation
From 126 feet to 50' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 155'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 20.93 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F. Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Carson Pump Contractor
Address P.O. Box 20159 Contractor
Carson City, NV. 89721
Nevada contractor's license number issued by the State Contractor's Board 39920
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1482
Signed Dan Granger
By driller performing actual drilling on-site or contractor
Date 11/16/2002

USE ADDITIONAL SHEETS IF NECESSARY