WHITE - DIVISION OF WATER RESOURCES
CANARY - CLIENT'S COPY
PINK - WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 98120
Permit No.
Basin 061

NOTICE OF INTENT NO. 50804

OWNER Barrick Goldstrike Mines PZ99-1
MAILING ADDRESS P.O. Box 29
Elko, NV 89803

ADDRESS AT WELL LOCATION Barrick Goldstrike minesite, north of Carlin, NV.

2. LOCATION SE 1/4 NW 1/4 Sec. 30 T 36N N/S R 50E E Eureka County

PERMIT NO. N/A (Issued by Water Resources) | N/A (Parcel No.) | N/A (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☒ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Original Construction Detail:				
Cement		0	50	50
Hole plug		50	314	264
Gravel pack		314	365	51
Hole plug		365	925	560
Gravel pack		925	992	67
Hole plug		992	1050	58
Abandoned both tubes by pumping neat cement from T.D. to surface.				
Quantities Used:				
(Neat Cement) 1: 32 cu.ft. 2: 15 cu.ft.				

RECEIVED 02 AUG -9 PM 12:04 STATE ENGINEER'S OFFICE

Date started 7/27/2002, 19__
Date completed 7/27/2002, 19__

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION

Depth Drilled 1050 Feet Depth Cased 978 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
19	Inches	0	Feet	50	Feet
8	Inches	50	Feet	555	Feet
7.875	Inches	555	Feet	1050	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
13.375	68.75	0.500	0	50
1: 2.375	3.65	0.154	+2	978
2: 2.375	3.65	0.154	+2	358

Perforations:
Type perforation Slot
Size perforation 0.125" X 4"
From 1: 938 feet to 978 feet
From 2: 318 feet to 358 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From See Detail feet to feet

9. WATER LEVEL
Static water level 1: 926 2: 328 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Lang Exploratory Drilling (Contractor)
Address P.O. Box 5279 (Contractor)
Elko, NV 89802-5279
Nevada contractor's license number issued by the State Contractor's Board 0021976
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1995
Signed Guadalupe Jacobo (By driller performing actual drilling on-site or contractor)
Date 8/2/02

USE ADDITIONAL SHEETS IF NECESSARY

BST